

C1 E-604 MEDIUM VOLTAGE SHORE POWER ONELINE
SCALE: NTS



A1 E-604 LOW VOLTAGE SHORE POWER ONELINE
SCALE: NTS

KEYNOTES:

1. PULL EXISTING (3) #2/0, #4G FROM DECOMMISSIONED COLD IRONING TRANSFORMER T-21 TO THE PRIMARY SIDE OF INSTALLED TRANSFORMER T-01 .
2. USE EXISTING (3) #1/0, #4G CONDUCTORS FROM DECOMMISSIONED TRANSFORMER T-21 TO DECOMMISSIONED COLD IRONING DISCONNECT D-21 T0 RUN THE CIRCUIT FROM TRANSFORMER T-01 TO SWITCHGEAR MAIN BREAKER.
3. PULL EXISTING (3) #2/0, #4G FROM DECOMMISSIONED COLD IRONING TRANSFORMER T-21 GOING BACK TO THE 13.2KV UTILITY POLE METER TO THE PRIMARY SIDE OF TRANSFORMER T-01.
4. PULL EXISTING (3) #600, #2G BACK FROM DECOMMISSIONED ISOLATION TRANSFORMER T-22 TO EXISTING VAULT V-107 AND ROUTE IT TO THE PRIMARY SIDE OF TRANSFORMER T-02.
5. USE REMAINING EXISTING (3) #600, #2G CONDUCTORS FROM KEYNOTE #3 T0 RUN THE SHORT LENGTH OF CONDUCTORS FROM TRANSFORMER T-02 TO PANEL BOARD PP-SPO.
6. TRANSFORMER SHALL INCLUDE IMPEDANCE GROUND. THE NEUTRAL GROUND RESISTOR SHALL BE 26 OHMS AND THE MINIMUM RATING SHALL BE 15A 5s AND 5A CONTINUOUS.

REVISION NAME-YYYY-MM-DD
FOR (SUBMITTAL NAME)
ISSUED: YYYY-MM-DD
NOT TO BE USED FOR CONSTRUCTION

DRAWING SCALES SHOWN BASED ON 22"X34" DRAWING

CONNECTICUT Port Authority

STATE PIER BERTH ELECTRIFICATION
STATE PIER COMPLEX
NEW LONDON, CONNECTICUT

ONE-LINE DIAGRAM

moffatt & nichol
160 WELLS AVENUE, SUITE 302
NEWTON, MA 02459
617 - 299 - 7330

SEAL

Sheet Reference No.
E-604
INDEX: INDX OF ----

File: P:\BCS\Projects\253654 CT State Pier Berth Electrification\100 CAD\2_Active_Sheets\M\253654E-604 - Plotted: 4/15/2026 12:13 PM by SVITU, HABEEB - Saved: 4/15/2026 12:12 PM by HSHITU